



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Janea Marking, Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: October 24, 2024
Issued by: Sacramento City Unified School District
**Project: Project #: 25-01161-1
eRate 28 Cabling Infrastructure**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. 24-1102-1 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD1.01 QUESTION

Lisbon (YPS) Campus Scope Change

AD1.01 ANSWER

Change the requirement **Cat6A Copper** ran from MPOE to MDF. New requirement will be: 12 Strand Single Mode Fiber from MPOE in main office to Room 14 Office. And an IDF Cabinet and all required equipment to make this a fully functional IDF. Run x10 **CAT6** copper to defined drops during the walk, and x2 **CAT6A** to a WAP location in the center of the room.

AD1.02 DRAWINGS

Maps were accidentally omitted from RFP. Use the following link to acquire maps:

<https://drive.google.com/drive/folders/1KwlmW5olW1dspTmwjP1MLzh9mioNxOZE?usp=sharing>

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid: